



Sertifikat Certificate

SERTIFIKAT

- O PREGLEDU TIPA / Type examination Broj / Number: T 2212
- POJEDINAČNI PREGLED / Single examination Strana / Page: 1 / 2

Na zahtev naručioca /
By the request of purchaser: **Ariston Thermo Croatia d.o.o., Kovinska 4a, 10000
Zagreb / Ariston Thermo Croatia**

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda
inspection of the new product**

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report: Broj / Number: T 2212

sa dokumentima u prilogu/
with attached documents: - Uputstvo za instaliranje i korišćenje / Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju K2487 2021 B 10, K2487 2021 B11 i K2487 2021 E9 TÜV Rheinland / Test reports K2487 2021 B 10, K2487 2021 B11 i K2487 2021 E9 TÜV Rheinland

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KONDENZACIONI KOTAO /
GAS CONDENSING BOILER**

proizveden od /
manufactured by: **Ariston Thermo SpA Via A. Merloni 45 Fabriano Italija
/ Italy**

oznaka - tip - serija /
mark - type - series: **ALTEAS ONE+NET ...
GENUS ONE+WIFI ...**
vrsta/type: C₁₃, C₃₃, C₄₃, C₅₃, C₈₃, B₂₃, B₃₃
kategorija/category: II_{2H3B/P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in: **Pravilnik o zahtevima za projektovanje, izradu i ocenjivanje usaglašenosti gasnih aparata ("Sl. gl. RS", br. 41/2015)
SRPS EN 15502-2-1:2013**

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 i Rešenja Ministarstva rudarstva i energetike br. 312-01-01508/2016-05 /
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012 and the decree of the Ministry of Mining and Energy N° 312-01-01508/2016-05.

Ocenjivanje sprovedeno / Evaluation performed from 01.03.2022. ÷ 14.03.2022.

izdat od / issued by:

INSTITUT MIHAJLO PUPIN
CENTAR ZA GASNU TEHNIKU/
INSTITUTE MIHAJLO PUPIN
GAS TECHNIQUE CENTRE

mesto, datum / place, date: M.P. /

Beograd, 14.03.2022.

Kristina Petković dipl.maš.inž.

Ime, Prezime / Name, Surname





Sertifikat Certificate

Prilog A /
Annex A

Broj / Number:

T 2212

Strana / Page:

2 / 2

oznaka - tip - serija /
mark - type - series :

ALTEAS ONE+NET ...
GENUS ONE+WIFI ...

vrsta/type: C₁₃, C₃₃, C₄₃, C₅₃, C₈₃, B₂₃, B₃₃
kategorija/category: II_{2H3B/P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
ALTEAS ONE+NET ... GENUS ONE+WIFI ...		
... 24	Q _n = 2,6 ÷ 22,0 (26,0*) kW P _n = 2,5 ÷ 21,5 kW P _n = 2,7 ÷ 23,6 kW** 2H: p= 20 mbar 3B/P: p = 30 mbar PMS=3 bar, PWM=7 bar	za grejanje i toplu sanitarnu vodu / for heating and domestic hot water
... 30	Q _n = 3,0 ÷ 28,0 (30,0*) kW P _n = 2,8 ÷ 27,5 kW P _n = 3,1 ÷ 30,3 kW** T _{max} =82°C, IPX5D, NO _x Class: 6	
... 35	Q _n = 3,5 ÷ 31,0 (34,5*) kW P _n = 3,3 ÷ 30,3 kW P _n = 3,6 ÷ 33,5 kW** 230V, 50 Hz, P _{el} =82/83/82W	
Napomena / note: * za toplu sanitarnu vodu / for domestic hot water ** za / for: 50-30 °C		

Bilo kakve promene na uređaju moraju se prijaviti izdavaocu ove isprave. / Any changes on the device must be reported to the issuer of this document

Definisani rok narednog pregleda je godinu dana u sklopu ocenjivanja Deklaracija usaglašenosti sa tipom! / The deadline for the next review is one year within the assessment of the Declaration of Conformity with the type!



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs