

Sertifikat Certificate



И 048 17

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
Volgina 15,
BEOGRAD SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781-02
impcgt@pupin.rs

SERTIFIKAT

O PREGLEDU TIPAA/ Type examination

Broj / Number:

T 1715

POJEDINAČNI PREGLED/Single examination

Strana / Page:

1/2

Na zahtev naručioca /
By the request of purchaser: **Ariston Thermo Croatia d.o.o., Kovinska 4a, 10000
Zagreb / Ariston Thermo Croatia**

preduzeto je/
has been undertaken: **Kontrolisanje novog proizvoda /
Inspection of the new product**

u vezi sa Izveštajem o usaglašenosti/
in relation to Inspection report:

Broj / Number:

T 1715

sa dokumentima u prilogu/
with attached documents: **- Prospekt proizvoda / Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu / Product documentation;
- Izveštaji o ispitivanju K19362017T3, K19362017B4
TÜV Rheinland / Test reports K19362017T3,
K19362017B TÜV Rheinland**

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet ocenjivanja /
subject of the inspection: **GASNI KONDENZACIONI KOTAO /
GAS CONDENSING BOILER**

proizveden od /
manufactured by: **Ariston Thermo SpA Via A. Merloni45 Fabriano
Italija / Italy**

oznaka - tip - serija /
mark - type - series: **CLASE ONE ... / CLASE ONE..
CLASE ONE SYSTEM ... / CLASE ONE SYSTEM..
vrsta/type: B₂₃, C₁₃, C₃₃
kategorija/category: II_{2H3P}**

kako je specificirano u Prilogu
A, zadovoljava zahteve
navedene u /
as specified in the Annex A,
meets the requirements listed in: **Pravilnik o zahtevima za projektovanje, izradu i
ocenjivanje usaglašenosti gasnih aparata ("Sl. gl.
RS", br. 41/2015) / Regulations on requirements
for design, construction and mark the conformity of
gas appliances SG RS 41/15**

Sertifikat o pregledu tipa se izdaje na osnovu Pravilnika o zahtevima za projektovanje, izradu
i ocenjivanje usaglašenosti gasnih aparata SG RS 41/15 .i

The inspection certificate is issued basis on the Regulations on requirements for design,
construction and mark the conformity of gas appliances SG RS 41/15.

izdat od / issued by :
**RUKOVODIOCA CENTRA ZA GASNU
TEHNIKU
GAS TECHNIQUE CENTRE MANAGER
Kristina Petković dipl.maš.inž.**

mesto, datum / place, date :

Beograd, 06.10.2017.



ime, Prezime / Name, Surname

SERTIFIKAT

Broj / Number:
T 1715

O PREGLEDU TIP/ Type examination

POJEDINAČNI PREGLED/Single examination

Strana / Page:
2/2

Prilog A / Annex A

oznaka - tip - serija /
mark - type - series :


CLASE ONE ... / CLASE ONE...
 CLASE ONE SYSTEM .. / CLASE ONE SYSTEM ..
 vrsta/type: **B₂₃, C₁₃, C₃₃**
 kategorija/category: **II_{2H3P}**

Sertifikat
Certificate

oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description
CLASE ONE 24	$Q_n=3,7 \div 22,0$ kW $P_n=3,4 \div 21,4$ kW $P_n=3,5 \div 24,9$ kW*)	- za grejanje i pripremu tople sanitarne vode (TSV) / for heating and preparation of domestic hot water (DHW)
CLASE ONE 30	$Q_n=4,3 \div 28,0$ kW $P_n=3,9 \div 27,4$ kW $P_n=4,1 \div 28,7$ kW*)	
CLASE ONE 35	$Q_n=5,0 \div 31,0$ kW $P_n=4,7 \div 30,2$ kW $P_n=4,8 \div 33,0$ kW*)	
CLASE ONE SYSTEM 24	$Q_n=3,7 \div 22,0$ kW $P_n=3,4 \div 21,4$ kW	- za grejanje / for heating
CLASE ONE SYSTEM 35	$Q_n=5,0 \div 31,0$ kW $P_n=4,7 \div 30,2$ kW	

Napomena / note: *) za / for: TSV/DHW

Bilo kakve promena na uređaju moraju se prijaviti izdavaocu ove isprave. / Any changes on the device must be reported to the issuer of this document



INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
 Volgina 15,
BEOGRAD SRBIJA
 tel: +381 11 6772 151
 fax: +381 11 6781-02
 impcgt@pupin.rs