CERTIFICATE

Certificate number: 2410759 (3)

Issued *15/10/2024*
Expires *08/10/2029*

Kiwa G3 Building Regulation (KUKG3) – Unvented Water Heater & KUKreg4 Certification

Evaluation Guideline – Kiwa UK – EG003 – Building Regulation G3
Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)
Model number(s) – see Appendix

Ariston S.p.A.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

The Building Regulations 2010 (England & Wales). Requirements G3, L1 & Regulation 7.

The Building (Scotland) Regulations 2004. Schedule 5, Section 6 clause 4.9, 6.3 & 6.4.

The Building Regulations (Northern Ireland) 2012. Part B clause 23 & Part P clause 88.

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.
Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.
See https://www.kiwa.com/gb/en/about-kiwa/water-products/ to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Ariston S.p.A
Viale Aristide Merloni 45 - 60044
Fabriano (AN) Italy.
Italy

kiwa approved KUK G3

kiwa approved KUKreg4

Product Certificate

Appendix to Certificate number: 2410759

The following products belong to this certificate

Product description:	Range of cased and insulated directly heated unvented water heater with an enamel coated steel cylinder. Fitted with a T&P valve set at 7 bar and 95°C, magnesium anode and an 8 bar expansion vessel. ATS3 – Without Production Surveillance.
Models:	VLS EVO 45 UK EU VLS EVO 80 UK EU VLS EVO WIFI 45 UK EU VLS EVO WIFI 80 UK EU VELIS PRO 45 UK VELIS PRO 80 UK VELIS TECH WIFI 45 UK 3K VELIS TECH WIFI 80 UK 3K
Size:	¾" BSP(M).
Scope:	Manufacturer recommended maximum working pressure 6 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C.
Marking:	Manufacturers name, serial number, year of manufacture and technical information on body.
Materials:	Non-metallic materials assessed (BS6920) to point of discharge.
Backflow protection notes:	Domestic unvented primary circuits may be filled or replenished by means of a temporary connection between the primary circuit and the supply pipe. An 'Approved' double check valve shall be installed at the point of connection to the supply pipe. A permanent connection between the primary circuit and the supply pipe may be made via a CA backflow prevention device or some other no less effective backflow prevention device.
Additional notes:	All water contact & exposed components satisfy opacity requirements. Sealed primary circuits and /or secondary hot water systems shall incorporate a means for accommodating the thermal expansion of water to prevent any discharge from the circuit and/or system except in an emergency situation.

Extra Notes: