Certificate

Certificate

2106749 (2)

Issued	21/06/2021
Valid until	31/12/2026

Kiwa UK Regulation 4 (KUKreg4) Approval

Kiwa hereby declares that legitimate confidence exists in the products specified and model number(s) listed in the Appendix for:

Ariston Thermo Spa.

meets the requirements as described in the
Evaluation Guideline – Kiwa UK – EG004 (Issue 7) – Regulation 4(1)(a)

Which verifies the requirements of reference standard(s):

Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification and is only valid in combination with the appendix.

David Jay
Business Unit Manager- Authorised
Signatory Kiwa Limited (Watertec)

This certificate relates to products intended to be used in the UK only. For other countries, other (National) requirements will apply.
Disclosure of the certificate is permitted in full.
To check the validity of a certificate, scan the QR code or go to https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/

kiwa CERTIFIED KUKreg4 ATS 3

UKAS PRODUCT CERTIFICATION 8896

KUKreg4

Kiwa Limited t/a: Watertec
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.com

CERTIFICATE HOLDER:
Ariston Thermo Spa
Viale Aristide Merloni 45
60044 Fabriano (AN)
ITALY

Appendix

The following products belong to this certificate

PRODUCT DESCRIPTION Electric instantaneous water heater having a plastic body. ATS3 – Without Production Surveillance.
MODEL(S) 3195216 AURES M 9.5 240V EU.
SIZE: ½" BSP (M).
SCOPE: Manufacturer recommended maximum working pressure 8 Bar & maximum operating temperature 57°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 57°C. Above ground use only.
MARKING Ariston, logo, AURES multi on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Consideration must be made on installation to the airgap arrangement.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes