CERTIFICATE

Certificate number: 2506709 (1)

Issued *17/06/2025*
Expires *17/06/2030*

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)
Model number(s) – see Appendix

Ariston S.p.A.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.
Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.
See https://www.kiwa.com/gb/en/about-kiwa/water-products/ or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Ariston S.p.A
Viale Aristide Merloni
45
Fabriano
60044
Italy

KUKreg4

Product Certificate

Appendix to Certificate number: 2506709

The following products belong to this certificate

PRODUCT DESCRIPTION Unvented 6 litre electrical storage heater incorporating a stainless-steel heating element and magnesium anode. The fitting is supplied with a safety relief valve set at 6.0 bar. ATS3 – Without Production Surveillance.
MODEL(S) Andris LUX 6 UR UK EU.
SIZE: ½" BSP (M).
SCOPE: Manufacturer recommended maximum working pressure 6.0 Bar & maximum operating temperature 100°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C
MARKING Ariston, model, pressure rating and other technical information on adhesive label on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Consideration must be made on installation to the airgap arrangement. A servicing valve shall be installed on the supply to the fitting in a readily accessible location.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. Sealed primary circuits and /or secondary hot water systems shall incorporate a means for accommodating the thermal expansion of water to prevent any discharge from the circuit and/or system except in an emergency situation.

Extra Notes