CERTIFICATE

Certificate number: 2410738 (2)

Issued *28/05/2026*
Expires *11/10/2029*

Kiwa G3 Building Regulation (KUKG3) – Unvented Water Heater & KUKreg4 Certification

Evaluation Guideline – Kiwa UK – EG003 – Building Regulation G3
Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)
Model number(s) – see Appendix

Ariston S.p.A

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

The Building Regulations 2010 (England & Wales). Requirements G3, L1 & Regulation 7.

The Building (Scotland) Regulations 2004. Schedule 5, Section 6 clause 4.9, 6.3 & 6.4.

The Building Regulations (Northern Ireland) 2012. Part B clause 23 & Part P clause 88.

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.
Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.
See https://www.kiwa.com/gb/en/about-kiwa/water-products/ to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Ariston S.p.A
Viale Aristide Merloni
45
Fabriano
60044
Italy

kiwa approved KUK G3

kiwa approved KUKreg4

Product Certificate

Appendix to Certificate number: 2410738

The following products belong to this certificate

Product description:	Cased and insulated directly heated unvented water heaters with enamel coated steel cylinders. The appliance is supplied with a control thermostat (set @ 60˚C) and high limit stat (set @ 88˚C) which is factory fitted. The cylinder is positioned within the casing and incorporates a factory fitted temperature pressure relief valve set at 90-95ºC at 7 bar (RWC). The appliance is supplied with a safety kit which includes an inlet group incorporating a pressure reducing valve set at 3.5 bar, expansion vessel, an expansion relief valve set at 6 bar, and a tundish for discharge to drain. Maximum working pressure up to the pressure reducing valve 16 bar. maximum working pressure 6 bar. ATS3 – Without Production Surveillance.
Models:	PRO1 ECO 50 V UK EU PRO1 ECO 80 V UK EU PRO1 ECO 100 V UK EU Models added May 2026: PRO1 ECO 50 S UK PRO1 ECO 80 S UK PRO1 ECO 100 S UK
Size:	See model.
Scope:	Manufacturer recommended maximum working pressure to the pressure reducing valve 16 Bar, maximum working pressure 5.5 bar & maximum operating temperature 88°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
Marking:	Adhesive label on casing with manufacturers name and address, maximum operating temperatures and technical information.
Materials:	Non-metallic materials assessed (BS6920) to point of discharge.
Backflow protection notes:	Sealed primary circuits and /or secondary hot water systems shall incorporate a means for accommodating the thermal expansion of water to prevent any discharge from the circuit and/or system except in an emergency situation.
Additional notes:	All water contact & exposed components satisfy opacity requirements. Expansion vessels should be installed in the vertical orientation, where expansion vessels are not installed in the vertical orientation appropriate measures should be used to ensure that there is adequate flow through of water through the expansion vessel and they are located so that the length of the connecting pipework is kept to a minimum.

Extra Notes: